

Ready Freddy the "Sewer Doer"

PUMPING - INSTALLING - EXCAVATING - SEWER LINE CLEANING

PHONE 752-4552

Send Payment To:

P.O. Box 5306
Kalispell, MT 59903

INV NO 51416

Date 17 NOV 20 20

Name HAL KRAUSE Phone 260-5478

Billing Address 171 PIONEER RD.

Location @ KALISPELL

Cash / Check#	Charge	<input checked="" type="checkbox"/> CC	CALLED JIM	AMOUNT
DESCRIPTION				
PUMPING	1000 GAL. FCP			300 -
EXTRA LOADS	Gravity			
RIDING AT:	High - A Little High - <u>Normal</u> - Low			
SOLIDS AT:	Low - <u>Normal</u> - A Little High - High			
INLET BAFFLE <input checked="" type="checkbox"/> On / <input type="checkbox"/> Off / Not Seen OUTLET BAFFLE <input checked="" type="checkbox"/> On / <input type="checkbox"/> Off / Not Seen				
CLEAN UP FEE: Removing Non-Biodegradable Items (*See Back)				NONE
RECOMMENDED PUMPING AGAIN: <u>Oct. 2025</u>				
CLEAN FILTER EVERY: N/A				
MILEAGE One Way, Over 20 Miles From Kalispell				
COMMENTS: <u>System Working normally</u> <u>at this time.</u>				
LABOR:				
PARTS:				
TOTAL				300 -

Authorized By [Signature] Arrive: 2:45 am/pm
Work Done By RAY / BRETT Leave: 3:15 am/pm

FREE ESTIMATES ON INSTALLATIONS • WORK CONDITIONALLY GUARANTEED

ALL PAST DUE ACCOUNTS WILL BE CHARGED 1.5% PER MONTH

Licensed Contractor - State Board of Health Licensed

THANK YOU!

****IMPORTANT NOTES****

- HAVE SEPTIC TANK PUMPED EVERY 3 - 5 YEARS.
- **NO GARBAGE!**
NO **BABY WIPES**, WOMEN'S PRODUCTS (Pads, Tampons, Applicators, Wipes)
CONDOMS, Q-TIPS, CIGARETTE BUTTS, ETC.
*DISCARDING THESE ITEMS INTO SEPTIC WILL RESULT IN A CLEANUP FEE, AS THEY HAVE TO BE PICKED UP AND REMOVED FROM DUMP SITE.
- **NO RUNNING TOILETS OR DRIPPING FAUCETS - RUINS DRAINFIELD.**
- HAVE WATER SOFTENERS SERVICED EVERY 4 - 5 YEARS, TO PREVENT CONSTANT LEAKING - RUINS DRAINFIELD.
- **NO IN TANK TOILET BOWL CLEANERS OR BLUE WATER IN TOILET.**
(These items kill all the bacteria in the septic tank)
- LIQUID SOAPS ARE RECOMMENDED IN WASHING MACHINES;
FOR DISHWASHERS, PLEASE USE SOAP TABS.
- IN ORDER TO MAINTAIN THE PROPER BACTERIAL ACTION WITHIN YOUR SEPTIC TANK WE RECOMMEND ADDING ONE BIG BOX OF POWDERED RID-X EVERY SIX MONTHS (SPRING / FALL) TO YOUR SEPTIC SYSTEM.
*WE DO NOT RECOMMEND FOLLOWING THE DIRECTIONS ON THE BOX.
- USE ONLY 2-PLY WHITE TOILET PAPER - NEVER SINGLE PLY.
(Single ply toilet paper takes longer to dissolve , creating a thick top layer that prevents proper functioning of your septic system. Some thick 2 plys, like Charmin and Kirkland will also clog your system.)

Regular use of bleach or cleaning chemicals can be damaging to the working bacteria in your septic system. For the benefit of your system - use chemicals on the same day and then allow **as many days as possible** before using them again.

IT IS ADVISABLE FOR YOU TO HAVE A COPY OF YOUR **SEPTIC SYSTEM PERMIT AND A DRAWING** OF THE LOCATION OF SEPTIC TANK AND DRAINFIELD. (We will need drawing to locate trouble spots, and will save time and money.) THE COUNTY WILL HAVE THESE ON FILE. CALL:

FLATHEAD COUNTY SANITATION DEPARTMENT (406) 751-8130

LAKE COUNTY SANITATION DEPARTMENT (406) 883-7235

This information may be faxed to us: READY FREDDY - Fax: 752-4580

*For Lids and Risers: Glacier Pre-Cast Concrete - 752-7163 or
Flathead Concrete Products - 752-4259